

Certificate of Compliance

Certificate Number 0070130-MH17883
Report Reference MH17883,19940124
Issue Date 2007 January 30

Page 1 of 1



**Underwriters
Laboratories Inc.®**

Issued to:

Steel Tank Institute, Div of STI/SPFA

570 Oakwood Rd.
Lake Zurich, IL 36502

*This is to certify that
representative samples of*

**Protected Aboveground Tanks for Flammable
and Combustible Liquids**

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*


Standard(s) for Safety:

**UL 2085 Protected Aboveground Tanks for Flammable and Combustible
Liquids**


Additional Information:


Listee's name, trade name, or trademark, a distinctive model designation or the equivalent, capacity of the primary containment tank, the month and year of manufacture, this tank requires emergency relief venting, the annular space requires emergency relief venting.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: 
John Silsdorf/Lead Engineering Associate
Underwriters Laboratories Inc.

Reviewed by: 
Milan Dotlich/Operations Manager
Underwriters Laboratories Inc.