



LEFT VIEW

FRONT VIEW WITH DOOR

OUTLINE_DRAWING

General Notes:

Minimum 14 gauge material
 17 Gallon Containment Pan
 304 stainless steel standard
 316 SS or powder coated carbon steel optional.
 Recessed, In-wall configuration
 Surface or tank mount optional
 120VAC Alarm Control Panel
 10Amp minimum circuit required.

Materials of Construction:

FILL BOX IS CONSTRUCTED WITH 14 GAUGE STAINLESS STEEL OPTIONAL.
 All welded and leak tested.

Fittings- All carbon steel SCH40.

Finish - #4 mill finish

Drawings are the property of MASCOTT EQUIPMENT COMPANY and cannot be reproduced or past to a third party. Drawings have not been prepared or reviewed by a licensed engineer and should be considered only as a customer service or representation of a finished product. Guaranteed performance requires certification by a licensed engineer.

DRAWING APPROVAL:

DATE:

		IN-WALL REMOTE FILL BOX-ROL			
		SIZE D	FSCM NO.	DWG NO. MEC3P60-44-19F	REV 0
435 NE Hancock Portland, Or 97212 PHONE (503) 282-2587 FAX (503) 288-9664		SCALE	SHEET 1 OF 1		