



OUTLINE\_DRAWING

**General Notes:**

Minimum 14 gauge material  
 7 Gallon Containment Pan  
 Carbon steel standard  
 304 or 316 SS optional  
 Recessed, in-wall configuration  
 Surface or tank mount optional  
 120VAC Alarm Control Panel  
 10Amp minimum circuit required.

**Materials of Construction:**

FILL BOX IS CONSTRUCTED WITH 14 GAUGE CARBON STEEL (STAINLESS STEEL OPTIONAL).  
 All welded and leak tested.

Fittings- All carbon steel SCH40.

Coating - powder coat zinc rich epoxy interior and exterior white, with a 2nd exterior coating of polyester.

Drawings are the property of MASCOTT EQUIPMENT COMPANY and cannot be reproduced or past to a third party. Drawings have not been prepared or reviewed by a licensed engineer and should be considered only as a customer service or representation of a finished product. Guaranteed performance requires certification by a licensed engineer.

DRAWING APPROVAL:

DATE:

		IN-WALL REMOTE FILL BOX	
		435 NE Hancock Portland, Or 97212 PHONE (503) 282-2587 FAX (503) 288-9664	SIZE D FSCM NO. SCALE
		SHEET 1 OF 1	